

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 25-Jan-2010	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) 09-0143
6. ISSUED BY NAVFAC MID ATLANTIC OFFICER IN CHARGE OF CONSTRUCTION MARINE CORPS INSTALLATIONS EAST 1005 MICHAEL ROAD CAMP LEJEUNE NC 28547-2521	CODE N40085	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. N40085-10-B-0212	
		X	9B. DATED (SEE ITEM 11) 22-Dec-2009	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 09-0143 CONSTRUCT METAL BUILDING TO HOUSE FITNESS WORKOUT FACILITY Bid Opening is hereby changed from 29 January 2010 @1:00 p.m. to 4 February 2010 @ 1:00 p.m. CLARIFICATION TO BIDDER INQUIRES				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		25-Jan-2010

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The following have been added by full text:

ADD the following:

"Contractor shall not begin construction of 8" water main without verification from Contracting Officer representative that an Authorization to Construct notice, if required, has been received from appropriate regulatory agency. Contractor shall not place water main into service without verification from Contracting Officer representative that all appropriate engineering and applicant certifications, if required, have been accepted and approved by the appropriate regulatory agency."

**CONSTRUCT METAL BUILDING TO HOUSE FITNESS WORKOUT FACILITY –
INCORPORATE INTO THE SOLICITATION THE BELOW QUESTIONS AND ANSWERS**

1. Question: What is the SEER rating for the AH/HP-2 split system heat pump?

Answer: The plans call for a 19 SEER rating for this unit. This is a nominal rating for a high efficiency series of equipment that one of our manufacturers produces. The actual SEER rating for this system should be 17.2.

2. Question: Spec section 01 30 00 1.5, states that the Site Superintendent may also serve as the QC Manager and the SSHO. Differently, in spec section 01 35 29 1.3 n, it states the QC cannot be the SSHO. Can the Site Superintendent serve as the QC and SSHO?

Answer: The site superintendent can also serve as the QC and SSHO.

3. Question: The Fire Alarm specs. don't say what type of Autonomous Control Unit that is needed. Do you have a certain ACU manufacture in mind? Does it need to be wireless?

Answer: The Autonomous Control Unit (ACU) shall be integrated with the fire alarm control panel to form one combined fire alarm/mass notification system. The ACU can be from a separate manufacturer than the FACP, or it can be part of the FACP. The ACU will monitor and control the notification appliance network and have the ability to allow personnel to initiate pre-recorded voice messages, live voice messages and initiate visual strobe notification appliances. The ACU shall not be a wireless unit, it is our understanding that Camp Lejeune is trying to steer away from wireless units.

4. Question: In the metal building spec it calls for manufacturer's standard vertical rib standing seam roof panel. There would be some significant cost savings going with a trapezoidal rib standing seam roof panel. The trapezoidal panel would still meet all uplift and weather tightness warrantee's specified but at a substantial cost savings. Would this be an acceptable alternative?

Answer: We have no objection if the "trapezoidal rib" standing seam roof panels meet or exceed the other specified requirements such as minimum gauge, 130mph wind design, finish, warranty, etc. Preferably, the standing seam roof panels are provided by the metal building manufacturer as part of the metal building package.

5. Question: The 50'-3" end wall frames are split into two equal bays of 25'-1 1/2" each. With the wind speed that needs to be designed for a bay spacing set up of 15'-1 1/2", 20'-0", 15'-1 1/2" would be more cost effective. I don't believe that an 8" girt, as specified on drawing S-2, would be able to withstand the 130 mph wind design called out for in the specs. Response to Item #1 below:

Answer: We have no objection to the additional columns. The contractor shall be responsible for including all other additional items, work, and costs in his/her bid as necessary for the proposed additional endwall columns. For example, the extra column footings, rebar, concrete, etc.

With the girts designed as 'inset' girts, the current span can be considered as a little less than a 25 foot span. Depending on the manufacturer's design choices, the manufacturer should be able to design the system to withstand the 130mph wind speed. The MB designer might choose to modify the girt spacing and "flange brace" the compression flanges to achieve the design strength.

(End of Summary of Changes)