

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 27-Jan-2010	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) 09-0143
6. ISSUED BY NAVFAC MID ATLANTIC OFFICER IN CHARGE OF CONSTRUCTION MARINE CORPS INSTALLATIONS EAST 1005 MICHAEL ROAD CAMP LEJEUNE NC 28547-2521		CODE N40085	7. ADMINISTERED BY (If other than item 6) See Item 6		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. N40085-10-B-0212	
			<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 22-Dec-2009	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. <p>Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 09-0143 CONSTRUCT METAL BUILDING TO HOUSE FITNESS WORKOUT FACILITY CLARIFICATION TO BIDDERS INQUIRES					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 27-Jan-2010

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The following have been added by full text:

**CONSTRUCT METAL BUILDING TO HOUSE FITNESS WORKOUT FACILITY –
INCORPORATE INTO THE SOLICITATION THE BELOW QUESTIONS AND ANSWERS**

1. Question: Will the GC only be responsible to stub telephone into the building?

Answer: As shown on detail 2/E6, telecommunication service is to be installed by division 26.

2. Question: If there is to be work done inside please provide the number of drops that will be required for this building and where telephone, coaxial/structured wiring or fiber optic outlets will be required. Specifically, is there any drawing showing the placement of drops and how many?

Answer: The number and locations of telecommunication drops is shown on sheet E4, there are three. The number and locations of coaxial outlets is shown on sheet E4, there are six. There are no fiber optic outlets on this project.

3. Question: Will this be for phone only? What kind of phone system will they be using and how do they want everything brought in to the telephone board and terminated (66 blocks, patch panels, etc.).

Answer: Phone system shall be by owner and is not shown on the drawings.

4. Question: Will any telecomm outlets be needed at exercise equipment?

Answer: None of the exercise equipment to our knowledge requires any telecommunication outlets.

5. Question: The Specs mention LEEDS in several places as well as obtaining LEED points. Please verify that this is just a guideline and this is not a LEED certified project.

Answer: Project design is in accordance with many standard LEED requirements, but the project will not be LEED certified. (The Government was originally going to pursue LEED Silver certification, but that requirement was deleted during the late stages of the design.)

6. Question: I find two different power supplies identified for the condensate unit specified in Sect. 23.22. Drawing sheet P-2 shows a 100A, 230V duplex controller electrical panel and Drawing E-2 shows 208/120V on the one-line diagram. With either voltage, will the power supply be 3 phase or single phase?

Answer: We really are not able to answer this question. It asks about items and sheets that to the best of our knowledge are not in the project. We have created the following list to identify the items that don't seem to match the project and we have also stated some items that may address their basic question.

- * There are not any condensate units in the project.
- * There is not a sheet P-2.
- * Sheet E-2 is an electrical site plan and does not show any diagrams.
- * Power for the building is 208V three phase.
- * Heat Pump HP-1 is three phase.
- * Heat Pump HP-2 is single phase. (due to availability)

7. Question: 1. In spec section 015719, page 9, sub section 3.6.3, It is stated that the government will provide pick-up and disposal service for garbage disposal. The next section references disposal off-site. Should we assume that the government will be responsible for pick up and disposal of garbage? Are we responsible for the fees associated with this?

Answer: Contractor is responsible for providing a dumpster, and for garbage pick-up and disposal.

8. Question: Can the bid and bid bond be submitted electronically?

Answer: Bids and bid bonds can not be electronically submitted, they can be handcarried to 1005 Michael Road, Camp Lejeune, NC or mailed to the same address.

9. Question: What are the procedures and directions for getting on the base to turn in this bid?

Answer: In order to gain access to the building to deliver a bid you must first stop at the Visitor center to the right of the main gate. Once you enter the Visitor Center, you must show proof of insurance, have a valid driver's license and current vehicle registration card and finally let them know that you are going to the OICC building at 1005 Michael Road.

10. Question: Are there liquidated damages?

Answer: Liquidated damages are in the amount of \$300.00 for each calendar day of delay until the work is completed or accepted. (See FAR 52.211-12 page 28 of 53).

11. Question: Is there anything else that must be turned to your office for the bid, beside pages 1-3 and a 20% bid bond?

Answer: Include pages 1-3 , 20% bid bond, all amendments, certification, unless bidding as OCRA.

12. Question: Will there be an official site visit?

Answer: There will be no official site visit, it will be the contractor's responsible to visit the site if you deem necessary.

13. Question: Where is French Creek Borrow Pit and is there a charge for the material?

Answer: There is no charge for the material and the borrow pit is located off McHugh Blvd behind the fire station and Burger King.

(End of Summary of Changes)